N5182A-08A S E R V I C E N O T E

Supersedes: N5182A-08

N5182A – MXG Vector Signal Generator

Serial Numbers: MY48180615 through MY48180800

Power supplies for a range of N5182A MXGs may incur an initial higher failure rate due to a minimally characterized lower level part.

Parts Required:

P/N Description Qty.

N5180-60060 A1 Power Supply 1 each

ADMINISTRATIVE INFORMATION

SERVICE NOTE CLASSIFICATION:				
MODIFICATION RECOMMENDED				
ACTION CATEGORY:	X ON SPECIFIED FAILURE [[]] AGREEABLE TIME	STANDARDS LABOR: 1.0 Hours		
LOCATION CATEGORY:	[[]] CUSTOMER INSTALLABLE X ON-SITE X SERVICE CENTER [[]] CHANNEL PARTNER	SERVICE [[]] RETURN INVENTORY: [[]] SCRAP X SEE TEXT	USED PARTS:	[[]] RETURN X SCRAP [[]] SEE TEXT
AVAILABILITY: January 1, 2011		NO CHARGE AVAILABLE UNTIL: January 1, 2011		
AUTHOR: AKS		PRODUCT LINE: 15		

ADDITIONAL INFORMATION:

This Service Note covers only Power Supply failures in the range of units described above; at the customers' site or at an Agilent Service Center.

© AGILENT TECHNOLOGIES, INC. 2010 PRINTED IN U.S.A.



July 12, 2010

Rev. 17

Page 2 of 2 N5182A-08A

Situation:

The N5182A MXG Signal Generator Power Supplies in this serial number range may have been built with a single lower level part that was not fully characterized or rated. The reliability of the power supply is very good with an Annual Fail Rate (AFR) of 0.25%. It is estimated that this lone part might increase the initial six month failure rate of the power supply by 2% to 2.25%. Units that will fail, show a failure in the 1st six months of usage. After six months the power supply reliability is once again normal with the AFR back to 0.25%.

Solution/Action:

The power supply part concern has been identified and resolved for all other serial number N5182A MXGs.

N5182A MXG units within these suspected serial number ranges, that fail due to a power supply failure (suspected related part or not), are approved and are covered under an extended warranty till January 1, 2011.